

IES Report

ZipTwo® | 707 | 40° Symmetric | 80 CRI | LO

707-Z2-4-48-XX-XX-X-0-Z-LO-35-S1-X-BL-0

	2700K	3000K	3500K	4000K
Efficacy - Lumens per Watt	36	37	38	39
Total Lumens, 4' rail length (1219mm)	578	596	608	620
Lumens per foot (305mm)	144	149	152	155
Input Power (W), 4' rail length (1219mm)	16.3	16.3	16.3	16.3
Watts per foot (305mm)	4.1	4.1	4.1	4.1
CRI	85	85	85	85

Due to the large number of options in Vode's product offering, most Vode IES reports are factored reports prepared from source reports. Source reports are the IES test reports prepared for Vode by an NVLAP accredited photometric test laboratory. Factored reports are based on data from the Vode source reports.

If the data above is in black, it is directly from a Vode source report. If it is in grey, it is factored from Vode source reports. Reference details on Vode source reports can be found on the [IES File Finder](#) page on [vode.com](#).



IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z2_LO_35_S1-BL.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L071704227 (SOURCE REPORT FOR REFERENCE)
[TESTLAB] REPORT BASED ON DATA PRODUCED BY NVLAP ACCREDITED LAB
[ISSUEDATE] 11/1/2017
[MANUFAC] Vode Lighting
[LUMCAT] 707-Z2-48-Z-LO-35-S1-BL
[LUMINAIRE] ZipTwo LED, 48", 3500K, 80 CRI, zipper board,
[MORE] 40° black symmetric lens, low output
[TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	606
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	37
Total Luminaire Watts	16.25
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	0.70
Spacing Criterion (90-270)	1.16
Spacing Criterion (Diagonal)	0.86
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.02 ft
Luminous Width (90-270)	4.02 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4743	13002	45311
55	2064	5641	26003
65	1307	2988	13444
75	915	1829	7318
85	905	905	3622

IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z2_LO_35_S1-BL.IES

CANDELA TABULATION

	<u>0</u>	<u>5</u>	<u>10</u>	<u>15</u>	<u>20</u>	<u>25</u>	<u>30</u>	<u>35</u>	<u>40</u>	<u>45</u>
0.0	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53
1.0	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53
3.0	566.40	566.40	566.40	566.40	566.99	566.99	567.58	567.58	568.17	568.17
5.0	556.37	556.37	556.37	556.96	557.55	558.14	559.32	560.50	561.09	562.27
7.0	538.67	538.67	539.26	540.44	541.62	543.39	545.16	547.52	549.88	552.24
9.0	515.07	515.07	516.25	518.02	520.38	522.74	526.28	529.82	533.95	538.08
11.0	486.16	486.75	488.52	490.88	494.42	498.55	503.27	508.58	514.48	520.97
13.0	452.53	453.12	455.48	458.43	463.15	469.05	475.54	483.21	491.47	500.32
15.0	414.77	415.95	418.31	422.44	428.34	436.01	444.27	454.30	464.92	475.54
17.0	374.65	375.24	378.78	384.09	390.58	399.43	410.05	421.85	434.83	448.40
19.5	323.32	324.50	328.04	333.94	342.20	352.82	365.21	379.96	395.30	412.41
22.5	261.37	262.55	266.68	273.17	282.61	294.41	308.57	325.09	343.97	364.03
25.5	204.14	205.32	209.45	215.94	225.38	237.77	253.11	270.81	291.46	313.88
29.0	147.50	148.68	152.22	158.71	167.56	179.36	194.11	211.81	233.05	256.65
33.0	96.76	97.94	100.89	106.20	113.28	123.31	136.29	152.22	171.10	194.11
37.5	57.82	58.41	60.77	64.31	69.62	77.29	87.32	99.71	115.64	135.11
42.5	31.86	32.45	33.63	35.99	39.53	44.25	50.74	59.59	71.39	85.55
47.5	18.29	18.29	19.47	20.65	23.01	25.37	29.50	35.40	42.48	51.92
55.0	8.85	8.85	9.44	10.03	10.62	11.80	13.57	15.93	19.47	24.19
65.0	4.13	4.13	4.13	4.13	4.72	5.31	5.90	6.49	7.67	9.44
75.0	1.77	1.77	1.77	1.77	1.77	2.36	2.36	2.95	2.95	3.54
85.0	0.59	0.59	0.59	0.59	0.59	0.59	0.59	0.59	0.59	0.59
90.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Vert. Angles **Horizontal Angles**

	<u>50</u>	<u>55</u>	<u>60</u>	<u>65</u>	<u>70</u>	<u>75</u>	<u>80</u>	<u>85</u>	<u>90</u>
0.0	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53
1.0	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53	570.53
3.0	568.17	568.76	569.35	569.35	569.35	569.94	569.94	569.94	569.94
5.0	563.45	564.63	565.81	566.40	567.58	568.17	568.17	568.76	568.76
7.0	554.60	556.96	558.73	561.09	562.86	564.04	565.22	565.81	565.81
9.0	542.21	545.75	549.88	553.42	556.37	558.73	560.50	561.68	561.68
11.0	526.87	532.77	538.67	543.98	548.70	552.24	555.19	556.96	557.55
13.0	509.17	517.43	525.10	532.77	539.26	543.98	548.11	550.47	551.65
15.0	487.34	498.55	508.58	519.20	527.46	534.54	539.26	542.80	543.98
17.0	462.56	476.72	490.29	503.27	513.89	522.74	529.23	533.36	534.54
19.5	430.11	447.81	464.33	480.85	495.01	506.22	515.07	520.97	522.74
22.5	385.86	407.69	429.52	449.58	467.28	482.62	494.42	500.91	503.27
25.5	339.25	364.03	389.99	414.18	436.01	454.89	469.05	477.90	480.85
29.0	282.61	311.52	339.84	369.34	395.30	418.31	435.42	446.04	450.17
33.0	220.66	249.57	280.84	313.29	342.79	368.75	389.40	401.79	405.92
37.5	158.71	185.85	216.53	245.44	278.48	306.21	329.22	343.38	348.10
42.5	103.84	126.26	151.63	178.18	207.68	233.05	256.65	270.81	276.12
47.5	64.90	80.24	99.12	121.54	145.14	167.56	185.85	198.24	202.96
55.0	30.68	38.35	48.97	61.95	74.34	88.50	100.30	108.56	111.51
65.0	11.80	14.75	18.29	23.01	27.73	33.04	37.76	41.30	42.48
75.0	4.13	5.31	6.49	7.67	9.44	11.21	12.98	14.16	14.16
85.0	1.18	1.18	1.18	1.77	1.77	1.77	2.36	2.36	2.36
90.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z2_LO_35_S1-BL.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	177.82	N.A.	29.30
0-30	324.64	N.A.	53.50
0-40	436.95	N.A.	72.00
0-60	564.76	N.A.	93.10
0-80	602.56	N.A.	99.40
0-90	606.49	N.A.	100.00
10-90	563.52	N.A.	92.90
20-40	259.13	N.A.	42.70
20-50	348.22	N.A.	57.40
40-70	154.65	N.A.	25.50
60-80	37.80	N.A.	6.20
70-80	10.96	N.A.	1.80
80-90	3.93	N.A.	0.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	606.49	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	42.97
10-20	134.85
20-30	146.83
30-40	112.30
40-50	89.09
50-60	38.73
60-70	26.84
70-80	10.96
80-90	3.93
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z2_LO_35_S1-BL.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	108	105	103	109	106	103	101	102	100	98	98	97	95	95	93	92	90
2	105	99	94	89	102	97	92	88	94	90	86	90	87	85	88	85	83	81
3	98	90	84	79	96	89	83	78	86	81	77	83	79	76	81	78	75	73
4	92	83	76	71	90	81	75	70	79	74	69	77	72	69	75	71	68	66
5	86	76	69	64	84	75	69	64	73	67	63	71	66	62	70	65	62	60
6	81	70	63	58	79	70	63	58	68	62	58	66	61	57	65	60	57	55
7	76	65	58	53	75	65	58	53	63	57	53	62	57	53	61	56	52	51
8	72	61	54	49	71	60	54	49	59	53	49	58	53	49	57	52	48	47
9	68	57	50	46	67	56	50	45	55	49	45	54	49	45	54	49	45	43
10	65	53	47	42	63	53	47	42	52	46	42	51	46	42	50	45	42	40

POLAR GRAPH



Maximum Candela = 570.53 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)